



- NOTE:
1. FOR DIMENSIONS SEE DETAIL SC-26
 2. ALL VALVES GREATER THAN 2" SHALL BE OS&Y GATE VALVES

* COMPOUND OR TURBINE MVR TYPE METER AS REQUIRED BY CITY OF BURLINGTON



DATE 8/16/04	REVISED 09/26/05	SCALE NOT TO SCALE	DETAIL SC-25
-----------------	---------------------	-----------------------	-----------------

4" WATER CONNECTION (SHEET 1 of 2)
CITY OF BURLINGTON, NORTH CAROLINA
ENGINEERING DEPARTMENT